

FFM-AUF-750I

Hollow Fiber Ultrafiltration Cylinder with internal pressure

| | | |
|----------------------------|----------------------|--------------------------------|
| PRODUCT DESCRIPTION | Membrane Chemistry: | Special Modified (PES) or (PS) |
| | Housing Shell: | PVC |
| | Potting Material: | Proprietary Epoxy Compound |
| | Through liquid tube: | PVC |

| PRODUCT SPECIFICATIONS | Typical design flux GFD (lmh) | Membrane Area ft ² (m ²) | Filtration accuracy um |
|------------------------|----------------------------------|--|---------------------------|
| | 30~60 (40~102) | 750ft ² / (70.0) | 0.01-0.03 |

OPERATION PARAMETERS

| | |
|--|------------------|
| Maximum operating pressure: | 45 psi (3.1bar) |
| Service temperature: | ≤104 °F (40°C) |
| Maximum backwashing pressure: | 30 psi (2.0 bar) |
| Maximum Operating Permeable Membrane Pressure Difference (TMP) : | 30 psi (2.0 bar) |
| PH tolerance range: | 1.5-13 |
| For special applications, please contact FFM Inc | |

Important Information

1. Before the installation of membrane components, the system and pipelines shall be completely cleaned to ensure that there is no mechanical impurity causing damage to the membrane.
2. Before the operation of the system, it shall be ensured that the pre-treatment is completed.
3. During the start-up, shutdown, cleaning and other processes of the system, the water inflow shall be slow, from low pressure to high pressure, from low flow to large flow, so as to avoid the impact damage to membrane components caused by the instantaneous rise of pressure and flow.
4. The membrane element should always be kept wet once water enters.
5. Back pressure on the water producing side should be avoided at all times.

